ОТИСК-4898

Approved by: Head of Zirabulak MGMC Gaffarov N.S. on 15.03.2017

Reply to letter of ATG # ATG-UTG-EN-20-17-06 dd 23.02.2017

**Technical assignment for connection to power networks**

| | | |
|---|---|---|
| 1 | Description of power supply | Substation 220-А РУ -5 НГМК |
| 2 | Description of consumer | JSC Uztransgaz Zirabulak MGMC |
| 3 | Description of sub-consumer | JV Asia Trans Gas LLC |
| 4 | Description of power accepting devices | Gas |
| 5 | Maximal power of connected power accepting devices of sub-consumer | 2 kwt |
| 6 | Reliability category | III |
| 7 | Voltage class by which the technological connection to be done | 0.4 kV |
| 8 | Connection point | 135 km Gazli-Chimkent Trunk Gas pipeline |
| 9 | Main power resource | Has no own power supply |
| 10 | Reserve power resource | No |
| 11 | For effecting power connection the sub-consumer will perform | 1. Organization of commercial custody of power based on metering device of accuracy class 0.5 "Energomer" on the border of balance participation with factory parameters for APCMS of JSC Uztransgas or upon agreement.<br>2. construction of HVL from connection point to installation place of TS and installation of individual РЛНД -10.<br>3. Performance of all required documentation of power supply in compliance with this technical assignment to get agree with power supervision of Navoiy region, enterprise of territorial power networks and Zirabulak MGMC.<br>4. Sub-consumer has no right to transfer power to other consumer without consent of UTG. |
| 12 | Expiry date of Technical Assignment | 1 year from the approval date |

Master of CP of Zirabulak MGMC: Tursunov Kh.N.

48-01-07/507
15.03.17

«УТВЕРЖДАЮ»
Начальник Зирабулакского УМГ
_____ Н.С.Гаффаров
«15» 03 2017 г.

*Ответ на письмо СП ООО «Asia Trans Gaz» за № ATG-UTG-EN-20-17-06 от 23.02.2017 г*

# ТЕХНИЧЕСКИЕ УСЛОВИЯ
## на присоединение к электрическим сетям

| | | |
|---|---|---|
| 1 | Наименование энерго-снабжающей | П/ст 220 – А РУ-5 НГМК |
| 2 | Наименование потребителя | АК «Узтрансгаз» Зирабулакское УМГ |
| 3 | Наименование субпотребителя | СП ООО «Asia Trans Gaz» |
| 4 | Наименование энергопринимающих устройств | газ |
| 5 | Максимальная мощность присоединяемых энергопринимающих устройств субпотребителя | 2 кВт |
| 6 | Категория надежности | III |
| 7 | Класс напряжений которым осуществляется технологическое присоединение | 0,4 кВ |
| 8 | Точка присоединение | 135 км МГ «Газли-Чимкент» |
| 9 | Основной источник питания | Собственный источник питания не имеет |
| 10 | Резервный источник питания | нет |
| 11 | Для обеспечения электроснабжения субабонент осуществляет | 1. Организацию коммерческого учёта электроэнергии на базе прибора учёта класс точности 0,5 «Энергомера» на границе балансовой принадлежности с заводскими данными на АСКУЭ АК «Узтрансгаз», либо по согласованию.<br>2. Строит. ВЛ от точки подключения до место установки ТП и установить отдельный РЛНД-10.<br>3. Выполнение всей необходимой документации электроснабжения в соответствии с настоящими техническими условиями согласовать с энергонадзора Навоинского области, предприятием территориальных электрических сетей и Зирабулакским УМГ.<br>4. Субабонент без согласования с АК «Узтрансгаз» не имеет право передавать электро энергию другому абоненту. |
| 12 | Срок действия ТУ | 1 год с момента утверждения |

Мастер ЭХЗ Зирабулакского УМГ: Турсунов Х.Н.